



Pace Analytical Services, LLC

2231 W. Altorfer Drive

Peoria, IL 61615

(800)752-6651

January 11, 2024

Melanie Wright
Bismarck R-V School District
165 Campus Drive
Bismarck, MO 63624

RE: Drinking Water Lead

Dear Melanie Wright:

Please find enclosed the analytical results for the **45** sample(s) the laboratory received on **12/26/23 2:45 pm** and logged in under work order **GL04277**. All testing is performed according to our current TNI accreditations unless otherwise noted. This report cannot be reproduced, except in full, without the written permission of Pace Analytical Services, LLC.

If you have any questions regarding your report, please contact your project manager. Quality and timely data is of the utmost importance to us.

Pace Analytical Services appreciates the opportunity to provide you with analytical expertise . We are always trying to improve our customer service and we welcome you to contact the General Manager, Lisa Grant, with any feedback you have about your experience with our laboratory at 309-683-1764 or lisa.grant@pacelabs.com.

A handwritten signature in black ink, appearing to read "Chenise Lambert-Sykes".

Chenise Lambert-Sykes
Project Manager
(314)432-0550
Chenise.Lambert-Sykes@pacelabs.com



SAMPLE RECEIPT CHECK LIST

Items not applicable will be marked as in compliance

Work Order GL04277

YES	Samples received within temperature compliance when applicable
YES	COC present upon sample receipt
YES	COC completed & legible
YES	Sampler name & signature present
YES	Unique sample IDs assigned
YES	Sample collection location recorded
YES	Date & time collected recorded on COC
YES	Relinquished by client signature on COC
YES	COC & labels match
YES	Sample labels are legible
YES	Appropriate bottle(s) received
YES	Sufficient sample volume received
YES	Sample containers received undamaged
NO	Zero headspace, <6 mm present in VOA vials
NO	Trip blank(s) received
YES	All non-field analyses received within holding times
NO	Short hold time analysis
YES	Current PDC COC submitted
NO	Case narrative provided



ANALYTICAL RESULTS

Sample: GL04277-01
Name: K Ice Machine
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:10
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 13:55, BRS, EPA 200.8 REV 5.

Sample: GL04277-02
Name: K Dishwasher
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:12
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 1.10, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 13:57, BRS, EPA 200.8 REV 5.

Sample: GL04277-03
Name: KF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:14
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 1.13, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 13:58, BRS, EPA 200.8 REV 5.

Sample: GL04277-04
Name: KF #2
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:16
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 1.14, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:05, BRS, EPA 200.8 REV 5.



ANALYTICAL RESULTS

Sample: GL04277-05
 Name: KF #3
 Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:18
 Received: 12/26/23 14:45
 PO #: FY24-00195

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/09/24 09:56	1	1.00	01/09/24 14:06	BRS	EPA 200.8 REV 5

Sample: GL04277-06
 Name: UEFW #1
 Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:28
 Received: 12/26/23 14:45
 PO #: FY24-00195

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/09/24 09:56	1	1.00	01/09/24 14:08	BRS	EPA 200.8 REV 5

Sample: GL04277-07
 Name: UEFW #2
 Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:29
 Received: 12/26/23 14:45
 PO #: FY24-00195

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/09/24 09:56	1	1.00	01/09/24 14:09	BRS	EPA 200.8 REV 5

Sample: GL04277-08
 Name: UEFW #3
 Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:31
 Received: 12/26/23 14:45
 PO #: FY24-00195

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/09/24 09:56	1	1.00	01/09/24 14:11	BRS	EPA 200.8 REV 5



ANALYTICAL RESULTS

Sample: GL04277-09
Name: UEWF #4
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:32
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row for Lead: < 1.00 ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:15, BRS, EPA 200.8 REV 5.

Sample: GL04277-10
Name: ETWF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:25
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row for Lead: < 1.00 ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:17, BRS, EPA 200.8 REV 5.

Sample: GL04277-11
Name: LEWF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:43
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row for Lead: < 1.00 ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:22, BRS, EPA 200.8 REV 5.

Sample: GL04277-12
Name: LEWF #2
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:44
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row for Lead: < 1.00 ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:23, BRS, EPA 200.8 REV 5.



ANALYTICAL RESULTS

Sample: GL04277-13
Name: LEWF #3
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:48
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:25, BRS, EPA 200.8 REV 5

Sample: GL04277-14
Name: LEWF #4
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:49
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:26, BRS, EPA 200.8 REV 5

Sample: GL04277-15
Name: ELF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:50
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:28, BRS, EPA 200.8 REV 5

Sample: GL04277-16
Name: JHWF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:59
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, 1.59, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:29, BRS, EPA 200.8 REV 5



ANALYTICAL RESULTS

Sample: GL04277-17
 Name: JHWF #2
 Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:02
 Received: 12/26/23 14:45
 PO #: FY24-00195

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/09/24 09:56	1	1.00	01/09/24 14:31	BRS	EPA 200.8 REV 5

Sample: GL04277-18
 Name: JHWF #3
 Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:04
 Received: 12/26/23 14:45
 PO #: FY24-00195

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/09/24 09:56	1	1.00	01/09/24 14:33	BRS	EPA 200.8 REV 5

Sample: GL04277-19
 Name: JHWF #4
 Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:06
 Received: 12/26/23 14:45
 PO #: FY24-00195

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	1.40	ug/L		01/09/24 09:56	1	1.00	01/09/24 14:40	BRS	EPA 200.8 REV 5

Sample: GL04277-20
 Name: IAWF #1
 Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:08
 Received: 12/26/23 14:45
 PO #: FY24-00195

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/09/24 09:56	1	1.00	01/09/24 14:42	BRS	EPA 200.8 REV 5



ANALYTICAL RESULTS

Sample: GL04277-21
Name: OCF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:58
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:43, BRS, EPA 200.8 REV 5

Sample: GL04277-22
Name: HSWF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 06:55
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:45, BRS, EPA 200.8 REV 5

Sample: GL04277-23
Name: 303 F #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:09
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:46, BRS, EPA 200.8 REV 5

Sample: GL04277-24
Name: 303 F #2
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:11
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:48, BRS, EPA 200.8 REV 5



ANALYTICAL RESULTS

Sample: GL04277-25
Name: 303 F #3
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:13
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:50, BRS, EPA 200.8 REV 5

Sample: GL04277-26
Name: 303 F #4
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:14
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:51, BRS, EPA 200.8 REV 5

Sample: GL04277-27
Name: 315 F #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:17
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:53, BRS, EPA 200.8 REV 5

Sample: GL04277-28
Name: NCWF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:20
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 14:54, BRS, EPA 200.8 REV 5



ANALYTICAL RESULTS

Sample: GL04277-29
Name: NCWF #2
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:21
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:02, BRS, EPA 200.8 REV 5

Sample: GL04277-30
Name: NCWF #3
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:25
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:04, BRS, EPA 200.8 REV 5

Sample: GL04277-31
Name: NCWF #4
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:26
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:05, BRS, EPA 200.8 REV 5

Sample: GL04277-32
Name: NGGWF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:35
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:07, BRS, EPA 200.8 REV 5



ANALYTICAL RESULTS

Sample: GL04277-33
Name: NGGWF #2
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:36
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:08, BRS, EPA 200.8 REV 5.

Sample: GL04277-34
Name: NGBWF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:35
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:10, BRS, EPA 200.8 REV 5.

Sample: GL04277-35
Name: NGBWF #2
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:36
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:11, BRS, EPA 200.8 REV 5.

Sample: GL04277-36
Name: NCSWF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:49
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:13, BRS, EPA 200.8 REV 5.



ANALYTICAL RESULTS

Sample: GL04277-37
Name: NCSWF #2
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:50
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:17, BRS, EPA 200.8 REV 5.

Sample: GL04277-38
Name: NCSWF #3
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:53
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:19, BRS, EPA 200.8 REV 5.

Sample: GL04277-39
Name: NCSWF #4
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:54
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:24, BRS, EPA 200.8 REV 5.

Sample: GL04277-40
Name: NCSF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 07:57
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row 1: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:25, BRS, EPA 200.8 REV 5.



ANALYTICAL RESULTS

Sample: GL04277-41
Name: PKWF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:10
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:27, BRS, EPA 200.8 REV 5.

Sample: GL04277-42
Name: PKKF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:12
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:28, BRS, EPA 200.8 REV 5.

Sample: GL04277-43
Name: FBFF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:29
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:30, BRS, EPA 200.8 REV 5.

Sample: GL04277-44
Name: FBFF #2
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:30
Received: 12/26/23 14:45
PO #: FY24-00195

Table with 10 columns: Parameter, Result, Unit, Qualifier, Prepared, Dilution, MRL, Analyzed, Analyst, Method. Row: Lead, < 1.00, ug/L, 01/09/24 09:56, 1, 1.00, 01/09/24 15:31, BRS, EPA 200.8 REV 5.



ANALYTICAL RESULTS

Sample: GL04277-45
Name: SBFCF #1
Matrix: Drinking Water - Grab

Sampled: 12/21/23 08:47
Received: 12/26/23 14:45
PO #: FY24-00195

Parameter	Result	Unit	Qualifier	Prepared	Dilution	MRL	Analyzed	Analyst	Method
Total Metals - PIA									
Lead	< 1.00	ug/L		01/09/24 09:56	1	1.00	01/09/24 15:36	BRS	EPA 200.8 REV 5



NOTES

Specifications regarding method revisions, method modifications, and calculations used for analysis are available upon request. Please contact your project manager.

* Not a TNI accredited analyte

Certifications

CHI - McHenry, IL - 4314-A W. Crystal Lake Road, McHenry, IL 60050

TNI Accreditation for Drinking Water and Wastewater Fields of Testing through IL EPA Accreditation No. 100279
Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17556

PIA - Peoria, IL - 2231 W. Altorfer Drive, Peoria, IL 61615

TNI Accreditation for Drinking Water, Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. 100230

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory Registry No. 17553

Drinking Water Certifications/Accreditations: Iowa (240); Kansas (E-10338); Missouri (870)

Wastewater Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

Solid and Hazardous Material Certifications/Accreditations: Arkansas (88-0677); Iowa (240); Kansas (E-10338)

SPMO - Springfield, MO - 1805 W Sunset Street, Springfield, MO 65807

USEPA DMR-QA Program

STL - Hazelwood, MO - 944 Anglum Rd, Hazelwood, MO 63042

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through KS KDHE Certification No. E-10389

TNI Accreditation for Wastewater, Solid and Hazardous Material Fields of Testing through IL EPA Accreditation No. - 200080

Illinois Department of Public Health Bacterial Analysis in Drinking Water Approved Laboratory, Registry No. 171050

Missouri Department of Natural Resources - Certificate of Approval for Microbiological Laboratory Service - No. 1050







Certified by: Chenise Lambert-Sykes, Project Manager

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM




CHAIN OF CUSTODY RECORD
 STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

1 CLIENT Bismarck R-V School District ADDRESS 165 Campus Drive CITY STATE ZIP 165 Campus Drive Bismarck, MO 63624 CONTACT PERSON Melanie Wright/Paul Williams	PROJECT LOCATION PROJECT NUMBER PHONE NUMBER (573) 734-6111 option 3 E-MAIL emw@pblbismarck65.org; cotton@bismarck65.org SAMPLER (PLEASE PRINT) Paul Williams SAMPLER'S SIGNATURE 	PURCHASE ORDER # PO # FY24-00195 DATE SHIPPED 	3 ANALYSIS REQUESTED DW Lead (Pb) <input checked="" type="checkbox"/> Turb Check <input checked="" type="checkbox"/>	(FOR LAB USE ONLY) LOGIN # <u>604277</u> LOGGED BY: <u>gsk</u> CLIENT: Bismarck R-V School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: _____
	MATRIX TYPES: WW-WASTEWATER DW-DRINKING WATER DWL-DRINKING WATER WWSL-SLUDGE NAL-NON AQUEOUS LIQUID LCLT-LEACHATE SOL-SOLID	BOTTLE COUNT PRES CODE PROVIDED	REMARKS First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples	
2 (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT) LEWF #2 LEWF #3 LEWF #4 ELF #1 JHWF #1 JHWF #2 JHWF #3 JHWF #4 JAWF #1 OCF #1 HSWF #1	DATE COLLECTED TIME COLLECTED SAMPLE TYPE COMP GRAB MATRIX TYPE BOTTLE COUNT PRES CODE PROVIDED	1- HCL 2- H2SO4 3- HNO3 4- NAOH 5- NA2S2O3 6- UNPRESERVED 7- OTHER		

5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE)
 (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE)
 RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE
 EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:
 RECEIVED BY: (SIGNATURE)  DATE TIME 12/22/23 11:55
 RECEIVED BY: (SIGNATURE)  DATE TIME 12/26/23 10:30
 RECEIVED BY: (SIGNATURE)  DATE TIME 1/11/25

6 I understand that by Initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample conformance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities.
 PROCEED WITH ANALYSIS AND QUALITY RESULTS: (INITIALS) PW

7 RELINQUISHED BY: (SIGNATURE)  DATE TIME 12/22/23 11:55
 RELINQUISHED BY: (SIGNATURE)  DATE TIME 12/26/23 10:30
 RELINQUISHED BY: (SIGNATURE)  DATE TIME 1/11/25

8 COMMENTS: (FOR LAB USE ONLY)
 SAMPLE TEMPERATURE UPON RECEIPT 10.7 °C
 CHILL PROCESS STARTED PRIOR TO RECEIPT YORN YORN YORN
 SAMPLE(S) RECEIVED ON ICE
 SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED
 DATE AND TIME TAKEN FROM SAMPLE BOTTLE 1/11/25

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD
STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

CLIENT ADDRESS	PROJECT NUMBER	PROJECT LOCATION	PURCHASE ORDER #	DATE SHIPPED	ANALYSIS REQUESTED	(FOR LAB USE ONLY)		
							PHONE NUMBER	E-MAIL
1 Bismarck R-V School District 165 Campus Drive 165 Campus Drive Bismarck, MO 63624 CONTACT PERSON Melanie Wright/Paul Williams	(573) 734-6111 option 3	mwright@bismarckr5.org; cotton@bismarckr5.org	PO # FY24-00195			LOGIN # <u>604277</u> LOGGED BY: <u>[Signature]</u> CLIENT: <u>Bismarck R-V School District</u> PROJECT: <u>Drinking Water Lead</u> PROJ. MGR.: <u>Chenise Lambert-Sykes</u> CUSTODY SEAL #: _____		
2 SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT) 303 F # 1 303 F # 2 303 F # 3 303 F # 4 315 F # 1 NCWF # 1 NCWF # 2 NCWF # 3 NCWF # 4 NGGWF # 1 NGGWF # 2	DATE COLLECTED 12-21-23 12-21-23 12-21-23 12-21-23 12-21-23 12-21-23 12-21-23 12-21-23 12-21-23	TIME COLLECTED 07:09 07:11 07:13 07:14 07:17 07:20 07:21 07:25 07:26 07:35 07:36	SAMPLE TYPE X X X X X X X X X	MATRIX TYPE DW DW DW DW DW DW DW DW DW DW	BOTTLE COUNT 1 1 1 1 1 1 1 1 1 1 1	PRES CODE PROVIDED 6 6 6 6 6 6 6 6 6 6 6	MATRIX TYPES: WW-WASTEWATER DW-DRINKING WATER DWL-DRINKING WATER WWL-SLUDGE MAS-NON AQUEOUS SOLID LCHT-LEACHATE DCSL-DCSL SOL-SOLID	REMARKS First Draw Samples FIRST DRAW SAMPLES FIRST DRAW SAMPLES FIRST DRAW SAMPLES FIRST DRAW SAMPLES FIRST DRAW SAMPLES FIRST DRAW SAMPLES FIRST DRAW SAMPLES FIRST DRAW SAMPLES FIRST DRAW SAMPLES FIRST DRAW SAMPLES
3 ANALYSIS REQUESTED DW Lead (Pb) <input checked="" type="checkbox"/> Turb Check <input checked="" type="checkbox"/>								
4 (FOR LAB USE ONLY) COMMENTS: (FOR LAB USE ONLY)								
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) (NORMAL) RUSH RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: PHONE # IF DIFFERENT FROM ABOVE:								
6 I understand that by initialing this box I give the lab permission to proceed with analysis, even though it may not meet all sample performance requirements as defined in the receiving facility's Sample Acceptance Policy and the data will be qualified. Qualified data may NOT be acceptable to report to all regulatory authorities. PROCEED WITH ANALYSIS AND QUALIFY RESULTS: (INITIALS) <u>PW</u>								
7 RELINQUISHED BY: (SIGNATURE) <u>[Signature]</u> DATE <u>12-22-23</u> TIME <u>11:22</u> RELINQUISHED BY: (SIGNATURE) <u>[Signature]</u> DATE <u>12-22-23</u> TIME <u>11:25</u> RELINQUISHED BY: (SIGNATURE) <u>[Signature]</u> DATE <u>12-26-23</u> TIME <u>14:15</u>								
8 COMMENTS: (FOR LAB USE ONLY) SAMPLE TEMPERATURE UPON RECEIPT <u>10.7</u> °C CHILL PROCESS STARTED PRIOR TO RECEIPT Y OR N SAMPLE(S) RECEIVED ON ICE Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED Y OR N DATE AND TIME TAKEN FROM SAMPLE BOTTLE								

REGULATORY PROGRAM (CIRCLE):	NPDES
MORBCA	RCRA
CCDD	TACO: RES OR IND/COMM

CHAIN OF CUSTODY RECORD
STATE WHERE SAMPLE COLLECTED MO

ALL HIGHLIGHTED AREAS MUST BE COMPLETED BY CLIENT (PLEASE PRINT)

CLIENT Bismarck R-V School District ADDRESS: 165 Campus Drive CITY, STATE, ZIP: Bismarck, MO 63624 CONTACT PERSON: Melanie Wright/Paul Williams		PROJECT LOCATION PROJECT LOCATION: [Blank] E-MAIL: [Blank]		PURCHASE ORDER # PO # FY24-00195 DATE SHIPPED: [Blank]		ANALYSIS REQUESTED DW Lead (Pb) <input checked="" type="checkbox"/> Turb Check <input type="checkbox"/>		(FOR LAB USE ONLY) LOGIN # 604277 LOGGED BY: [Signature] CLIENT: Bismarck R-V School District PROJECT: Drinking Water Lead PROJ. MGR.: Chenise Lambert-Sykes CUSTODY SEAL #: [Blank]							
SAMPLE DESCRIPTION (UNIQUE DESCRIPTION AS IT WILL APPEAR ON THE ANALYTICAL REPORT) NGBWF #1 NGBWF #2 NCSWF #1 NCSWF #2 NCSWF #3 NCSWF #4 NCSF #1 PKWF #1 PKKF #1 FBFF #1 FBFF #2		DATE COLLECTED 12-21-23 12-21-23 12-21-23 12-21-23 12-21-23 12-21-23 12-21-23 12-21-23 12-21-23 12-21-23 12-21-23 12-21-23		TIME COLLECTED 07:35 07:36 07:49 07:50 07:53 07:54 07:57 08:10 08:12 08:29 08:30		SAMPLE TYPE X X X X X X X X X X X		MATRIX TYPE DW DW DW DW DW DW DW DW DW DW DW DW		BOTTLE COUNT 1 1 1 1 1 1 1 1 1 1 1 1 1		PRES CODE CLIENT PROVIDED 6 6 6 6 6 6 6 6 6 6 6 6		REMARKS First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples First Draw Samples	
5 TURNAROUND TIME REQUESTED (PLEASE CIRCLE) (RUSH TAT IS SUBJECT TO PACE LABS APPROVAL AND SURCHARGE) RUSH RESULTS VIA (PLEASE CIRCLE) EMAIL PHONE EMAIL IF DIFFERENT FROM ABOVE: [Blank] PHONE # IF DIFFERENT FROM ABOVE: [Blank]		6 DATE RESULTS NEEDED [Blank]		7 CHEMICAL PRESERVATION CODES: 1-HCL 2-H2SO4 3-HNO3 4-NAOH 5-NA2S2O3 6-UNPRESERVED 7-OTHER		8 COMMENTS: (FOR LAB USE ONLY) [Blank]		9 SAMPLE TEMPERATURE UPON RECEIPT: 10.7 °C CHILL PROCESS STARTED PRIOR TO RECEIPT: Y OR N SAMPLE(S) RECEIVED ON ICE: Y OR N SAMPLE ACCEPTANCE NONCONFORMANT REPORT IS NEEDED: Y OR N							
RECEIVED BY: (SIGNATURE) [Signature]		RECEIVED BY: (SIGNATURE) [Signature]		RECEIVED BY: (SIGNATURE) [Signature]		RECEIVED BY: (SIGNATURE) [Signature]		DATE AND TIME TAKEN FROM SAMPLE BOTTLE 12-22-23 11:22 12-22-23 11:25 12-22-23 11:25							

